

Appendix G

The QA/QC Procedures and Results

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: R-E Site No.: Am1
 Date of visit: 7-12-2001 Hour of Visit: 1115
 Staff name: W.L. MAK HVAS S/N: 2198
 Used filter paper no.: L012 New filter paper no.: L014
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 23.6}{296.6}$ K Pressure, $P_a = 1014$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading (ΔH_{STD}) corresponds to $Q_{STD} = 40 \text{ ft}^3/\text{min}$.	Manometer reading at site conditions
EV08B01	5.1 (4/01)	$\Delta H_a = 1.500(P_a/T_a) = \underline{\hspace{2cm}}$
✓EV08B02	5.0 (3/01)	$\Delta H_a = 1.471(P_a/T_a) = 5.02$

Manometer reading before calibration: 5.00

Adjustment of flow controller (Y/N): N

Manometer reading after calibration: 5.00

Note: Manometer reading corrected to ambient conditions: $\Delta H_a = \Delta H_{STD}(P_a/P_{STD})(T_{STD}/T_a)$

III. General Conditions of HVAS

IV. Remarks

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: EG Site No.: AM2
 Date of visit: 1-12-2001 Hour of Visit: 11:35
 Staff name: W.L. MAK HVAS S/N: 21P5
 Used filter paper no.: L013 New filter paper no.: L015
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 23.1}{296.1}$ K Pressure, $P_a = 1019$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading (ΔH_{STD}) corresponds to $Q_{STD} = 40 \text{ ft}^3/\text{min}$.	Manometer reading at site conditions
EV08B01	5.1 (4/01)	$\Delta H_a = 1.500(P_a/T_a) = \underline{\hspace{2cm}}$
<input checked="" type="checkbox"/> EV08B02	5.0 (3/01)	$\Delta H_a = 1.471(P_a/T_a) = \underline{5.06}$

Manometer reading before calibration: 5.20

Adjustment of flow controller (Y/N): Y

Manometer reading after calibration: 5.10

Note: Manometer reading corrected to ambient conditions: $\Delta H_a = \Delta H_{STD}(P_a/P_{STD})(T_{STD}/T_a)$

III. General Conditions of HVAS

IV. Remarks

PARTISOL TSP SAMPLER
SITE VISIT LOG SHEET

Site Name ASH LAGOON Site Number AM3
Date of Visit 7-12-2001 Hour of Visit 13:45
Staff Name W.L MAK Partisol S/N: 2000B 2011 20001
Used Filter No.: PA45 New Filter No.: PA46
Ambient temperature: 23.7 Ambient pressure: 1016

I. General Services

1. Replace control unit Large In-line Filter x
2. Clean the sample inlet head ✓
3. Clean sample tube ✓
4. Clean / ~~Replace~~ pump head ✓
5. Clean / Replace piston x

II. Operational Audits (3 months interval as recommended by manufacturer)

1. Temperature Check (Ambient temperature $\pm 2^{\circ}\text{C}$)

_____ $^{\circ}\text{C}$ Calibration: Y/N _____ $^{\circ}\text{C}$
Before After

2. Pressure Check (Ambient pressure ± 20 mbar)(factor = 0.000987)

_____ mbar Calibration: Y/N _____ mbar
Before After

3. Flow Check (16.7 \pm 1.1 litre/min)

_____ cc/min Calibration: Y/N _____ cc/min
Before After

III. Remarks

MINI VOLUME AIR SAMPLER

SITE VISIT LOG SHEET

Site Name: TYV Site No.: AM4
Date of visit: 7-12-201 Hour of Visit: 11:12
Staff name: H.K Tsang MINIVOL S/N: 2050
Used filter paper no.: MF08 New filter paper no.: MF10
Type of filter: ~~Cellulose~~ / Glass-fibre
(Delete as appropriate)

I. Calibration is performed by using Drycal DC-2 Flow Calibrator
5 Sl/min set point is recommended

5.00 Before 5.00 After

II. General Service of Mini Vol Air Sampler

1. Clean Rotameter: ✓
2. Clean / ~~replace~~ Pump Valves: ✓
3. Clean / ~~replace~~ Pump Diaphragms: ✓
4. Clean Impaction Inlet: ✗
5. Replace Timer Battery Every 6 months: ✗
6. Replace Inlet Filter: ✓

III. Remarks

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
TEOM 1400A CONTINUOUS DUST MONITOR
DATA QUALITY ASSURANCE LOG SHEET

Month : DEC. Year : 2001

Reservoir (AM1)					
Date	Frequency (Hz) (260 – 280)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
6-12-01	269.11	0.059	4	1.00	15.65
12-12-01	268.53	0.021	4	1.00	15.65
18-12-01	272.94	0.029	4	1.00	15.65
24-12-01	272.57	0.016	4	1.00	15.65
30-12-01	272.08	0.043	4	1.00	15.65

East Gate (AM2)					
Date	Frequency (Hz) (230 – 250)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
6-12-01	248.42	0.036	4	1.00	15.66
12-12-01	245.16	0.028	4	1.00	15.65
18-12-01	246.07	0.030	4	1.00	15.64
24-12-01	245.77	0.028	4	1.00	15.64
30-12-01	245.36	0.052	4	1.00	15.64

Ash Lagoon (AM3)					
Date	Frequency (Hz) (230 – 250)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
6-12-01	246.64	0.022	4	0.99	15.64
12-12-01	246.43	0.033	4	1.00	15.64
18-12-01	246.12	0.027	4	1.00	15.64
24-12-01	245.83	0.026	4	0.99	15.64
30-12-01	247.36	0.022	4	1.00	15.65

Maintenance Record			
	Reservoir	East Gate	Ash Lagoon
TEOM Filter Exchange	✓	✓	✓
Clean TSP Inlet	✓	✓	✓
Replace flow in-line filter			
Pump Repair			
Leak Check			
Flow Audit			
Flow Controller Calibration			
A/C filter cleaning	✓	✓	✓

Remarks:

Prepared by : Alex

Checked by : Col

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/~~Ching Lam*~~
Date 13-12-2001 Time 11:40
Equipment Rion NA-27 Sound Level Meter
Serial Number ~~00111465~~/00111466/~~00111467*~~
Staff Attended H.K. TSANG

1. Calibration

Acoustic calibrator used	<u>Rion NC-74</u>
Calibration level before adjustment (dB(A))	<u>93.9</u>
Calibration level after adjustment (dB(A))	<u>94</u>

2. Weather Conditions

- a. ~~Sunny/fine/cloudy/showery/heavy rain*~~
b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/Ching Lam*
Date 14-12-2001 Time 1145-
Equipment Rion NA-27 Sound Level Meter
Serial Number 00111465/00111466/00111467*
Staff Attended W L MAK, H K. TSANG

1. Calibration

Acoustic calibrator used Rion NC-74
Calibration level before adjustment (dB(A)) 93.9
Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

a. ~~Sunny/fine/cloudy/showery/heavy rain*~~
b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

Equipment Calibration Record

Equipment No.	CM-ESG-022	Equipment description	YSI 6820 Multi-parameter Water Quality Monitor
Calibration method reference	OD-ESG-075	Calibration equipment used (if any)	--

Use of Reference material (if any)	pH	DO	Turbidity
	pH 6.86 & 10.01 buffer RM ESG-006 RM ESG-007	--	0 NTU & 200 NTU RM-ESG-0002 RM-ESG-0003
Permissible tolerance of calibration	± 0.12 pH	±5%	±5%

Calibration Result

Date	Standard	pH		DO	Turbidity		Calibrated by
		6.86	10.01	100%	0	200	
3/12	Before	6.95	10.28	98.4	0.5	203.1	Torch
	After	6.86	10.01	100.0	0.0	200.0	
5/12	Before	6.90	10.14	99.1	1.2	202.1	Torch
	After	6.86	10.01	100.0	0.0	200.0	
7/12	Before	6.87	10.24	98.8	2.4	203.5	Torch
	After	6.86	10.01	100.0	0.0	200.0	
10/12	Before	6.82	9.97	99.8	1.6	202.1	Torch
	After	6.86	10.01	100.0	0.0	200.0	
12/12	Before	6.97	10.08	95.3	0.0	205.2	Torch
	After	6.86	10.01	100.2	0.0	200.0	
14/12	Before	6.70	10.07	105.0	0.7	202.2	Torch
	After	6.86	10.01	100.1	0.0	200.0	
18/12	Before	6.91	9.98	103.5	2.0	198.3	Torch
	After	6.86	10.01	100.0	0.0	200.0	
20/12	Before	6.97	9.89	98.3	1.0	201.8	Torch
	After	6.86	10.01	100.0	0.0	200.0	
22/12	Before	6.87	9.92	103.4	0.4	203.6	Torch
	After	6.86	10.01	100.0	0.0	200.0	
24/12	Before	6.80	10.07	104.1	0.6	202.1	Torch
	After	6.86	10.01	100.0	0.0	200.0	
26/12	Before	6.90	10.08	98.2	0.5	200.5	Torch
	After	6.86	10.01	100.0	0.0	200.0	
28/12	Before	6.92	9.95	99.5	1.3	196.4	Torch
	After	6.86	10.01	100.0	0.0	200.0	
31/12	Before	6.88	10.05	98.3	0.7	200.3	Torch
	After	6.86	10.01	100.0	0.0	200.0	
	Before						
	After						

Approved by EMC: _____

Date: 2/1/2002

SUMMARY OF QUALITY CONTROL DATA - BLANK RESULTS

Parameter	Control Limit	Blank ID	Measured Value	Blank ID	Measured Value	Blank ID	Measured Value	Blank ID	Measured Value	Blank ID	Measured Value	Blank ID	Measured Value
Suspended Solids mg/L	< 1	BK0113004	< 1	BK0112010	< 1	BK0112013	< 1	BK0112119	< 1	BK0112024	< 1	BK0112028	< 1
		BK0112104	< 1	BK0112110	< 1	BK0112113	< 1	BK0112219	< 1	BK0112124	< 1	BK0112128	< 1
		BK0112204	< 1	BK0112210	< 1	BK0112213	< 1	BK0112319	< 1	BK0112224	< 1	BK0112228	< 1
		BK0112004	< 1	BK0112310	< 1	BK0112313	< 1	BK0112419	< 1	BK0112324	< 1	BK0112328	< 1
		BK0112006	< 1	BK0112111	< 1	BK0112115	< 1	BK0112021	< 1	BK0112027	< 1	BK0112029	< 1
		BK0112106	< 1	BK0112211	< 1	BK0112215	< 1	BK0112121	< 1	BK0112127	< 1	BK0112129	< 1
		BK0112206	< 1	BK0112011	< 1	BK0112315	< 1	BK0112221	< 1	BK0112227	< 1	BK0112229	< 1
		BK0112306	< 1	BK0111311	< 1	BK0112415	< 1	BK0112321	< 1	BK0112327	< 1		
Unionized Ammonia (as Ammonia) mg/L	< 0.01	BK0112021	< 0.01										
		BK0112121	< 0.01										
		BK0112220	< 0.01										
Total Inorganic Nitrogen (as Nitrite and Nitrate) mg/L	< 0.01	BK0112020	< 0.01										
		BK0112120	< 0.01										
		BK0112220	< 0.01										

Total: 47

Total: 3

Total: 3

SUMMARY OF QUALITY CONTROL DATA - DUPLICATE RESULTS

Parameter	Control Limit	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value		
Suspended Solids mg/L	exceed 20%	WC0118022	6.9	WC0118205	4.1	WC0118378	11.4	WC0118666	7.4	WC0119179	3.1	WC0119603	5.1		
			6.3		4.1		11.4		7.0		3.3		5.3		
		WC0118037	14.6	WC0118220	7.6	WC0118393	7.3	WC0118681	17.8	WC0119194	8.7	WC0119618	11.0	WC0119639	10.6
			15.2		7.8		7.1		17.0		8.7		11.0		
		WC0118058	9.4	WC0118241	8.5	WC0118414	12.2	WC0118702	11.5	WC0119214	6.5	WC0119639	4.8	WC0119654	4.2
			9.4		8.5		11.4		10.3		6.9		4.2		
		WC0118073	9.5	WC0118256	6.1	WC0118429	15.5	WC0118717	12.5	WC0119230	10.2	WC0119654	8.0	WC0119832	8.0
			9.3		6.3		16.7		13.7		11.0		9.2		
		WC0118110	11.0	WC0118289	9.5	WC0118490	8.1	WC0118898	9.9	WC0119523	7.7	WC0119832	15.6	WC0119847	16.0
			10.6		8.9		8.1		9.9		7.9		16.0		
		WC0118125	13.8	WC0118304	10.6	WC0118505	11.7	WC0118914	12.6	WC0119538	12.9	WC0119847	9.7	WC0119868	9.7
			14.0		9.6		13.3		12.4		12.5		8.9		
		WC0118146	8.9	WC0118325	12.7	WC0118526	17.2	WC0118935	15.0	WC0119559	7.6	WC0119868	8.9	WC0119874	8.9
			8.9		12.5		18.8		17.4		7.8		9.1		
		WC0118161	10.0	WC0118340	9.9	WC0118541	12.5	WC0118950	10.3	WC0119574	10.5	WC0119574	10.5	WC0119574	10.5
10.2	9.1		11.9		10.3		10.7		10.7						
Unionised Ammonia (as Ammonia) mg/L	exceed 20%	WC0118022	0.001	WC0118022	0.001	WC0118037	0.003	WC0118037	0.003	WC0118058	0.001	WC0118058	0.001		
			0.003		0.003		0.001		0.001						
		WC0118037	0.003	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001
			0.003		0.001		0.001		0.001		0.001				
		WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001	WC0118058	0.001
Total Inorganic Nitrogen (as Nitrite + Nitrate) mg/L	exceed 20%	WC0118022	0.15	WC0118022	0.15	WC0118037	0.22	WC0118037	0.22	WC0118058	0.14	WC0118058	0.14		
			0.15		0.22		0.22		0.14		0.14				
		WC0118037	0.22	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14
			0.22		0.14		0.14		0.14		0.14				
		WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14	WC0118058	0.14
													Total: 47		
													Total: 3		
													Total: 3		

SUMMARY OF QUALITY CONTROL DATA - MATRIX SPIKE RESULTS

Parameter	Spiked ID	Recovery (%)	Spiked ID	Recovery (%)	Spiked ID	Recovery (%)	Spiked ID	Recovery (%)	Spiked ID	Recovery (%)	Spiked ID	Recovery (%)
Unionized Ammonia (as Ammonia) mg/L	RT0102121	94										
	RT0102221	102										
	RT0102321	99										
Total Inorganic Nitrogen (as Nitrite + Nitrate) mg/L	RT0112120	103										
	RT0112220	113										
	RT0112022	113										

Total: 3

Total: 3

Acceptance Criteria: 75% to 125%

SUMMARY OF QUALITY CONTROL DATA - QC SAMPLES RESULTS

Parameter	Control Limit	QC ID	Measured Value	QC ID	Measured Value	QC ID	Measured Value	QC ID	Measured Value	QC ID	Measured Value	QC ID	Measured Value
Suspended Solids mg/L	8.9 - 10.3	QC0113004	9.4	QC0112010	9.7	QC0112013	9.5	QC0112119	9.4	QC0112024	9.2	QC0112028	9.4
		QC0112104	9.3	QC0112110	9.4	QC0112113	9.6	QC0112219	9.5	QC0112124	9.5	QC0112128	10.2
		QC0112204	10.3	QC0112210	9.7	QC0112213	9.3	QC0112319	9.2	QC0112224	9.4	QC0112228	10.2
		QC0112004	10.1	QC0112310	9.6	QC0112313	9.5	QC0112419	9.7	QC0112324	9.8	QC0112328	9.4
		QC0112006	10.1	QC0112111	9.3	QC0112115	9.5	QC0112021	9.6	QC0112027	9.5	QC0112029	9.5
		QC0112106	9.6	QC0112211	9.9	QC0112215	9.6	QC0112121	9.5	QC0112127	9.2	QC0112129	10.0
		QC0112206	9.4	QC0112047	9.4	QC0112315	9.6	QC0112221	9.9	QC0112227	9.6	QC0112229	9.3
		QC0112306	9.6	QC0111231	9.7	QC0112415	9.3	QC0112321	10.1	QC0112327	9.9		
Unionized Ammonia (as Ammonia) mg/L	0.09 - 0.12	QC0112021	0.10										
		QC0112121	0.10										
		QC0112221	0.10										
Total Inorganic Nitrogen (as Nitrite and Nitrate) mg/L	0.36 - 0.44	QC0112020	0.40										
		QC0112120	0.41										
		QC0112220	0.41										

Total: 47

Total: 3

Total: 3

SUMMARY OF QUALITY CONTROL DATA - BLIND DUPLICATE RESULTS

Parameter	Control Limit	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value	Sample ID	Measured Value			
Suspended Solids mg/L	exceed 20%	WC0118082	15.9	WC0118170	17.4	WC0120126	5.5	WC0118349	7.1	WC0118438	6.1	WC0118550	7.7	WC0118726	7.7	WC0118959	10.5	WC0119239	9.0	WC0119583	6.1	WC0119663	8.6	WC0119892	9.3			
			14.1		15.8		5.1		7.4		6.4		7.1		7.8		9.9		8.3		6.1		9.5		8.6			
		WC0118083	7.7	WC0118171	9.6	WC0118266	12.3	WC0118350	8.3	WC0118439	9.3	WC0118551	9.9	WC0118727	7.1	WC0118960	17.5	WC0119240	5.2	WC0119241	4.9	WC0119584	11.5	WC0119664	6.2	WC0119898	10.3	
			6.9		9.2		11.9		9.2		9.4		9.9		7.4		18.7		4.9		12.5		5.9		10.1			
		WC0120125	8.3	WC0118172	9.2	WC0118267	10.1	WC0118351	4.9	WC0118440	8.1	WC0118552	13.7	WC0118728	29.9	WC0118961	14.1	WC0119242	8.0	WC0119243	8.3	WC0119585	13.1	WC0119665	11.4	WC0119894	10.3	
			7.6		9.2		10.0		4.2		8.1		14.9		29.2		14.2		8.3		10.7		8.5					
		WC0118085	24.1	WC0118173	15.4	WC0118268	6.9	WC0118352	9.9	WC0118441	9.3	WC0118553	10.1	WC0118729	9.3	WC0118962	11.3	WC0119244	13.2	WC0119245	13.2	WC0119586	14.9	WC0119666	8.4	WC0119895	10.9	
			22.6		14.6		6.2		10.4		9.7		9.7		8.8		12.4		13.2		14.9		7.6		11.1			
		WC0118086	10.1	WC0118174	13.0	WC0118269	8.5	WC0120127	11.9	WC0118442	8.9	WC0118554	6.7	WC0120129	9.5	WC0118963	15.1	WC0119246	10.6	WC0119247	11.3	WC0119587	8.7	WC0119667	11.0	WC0119899	8.7	
			11.2		12.0		8.8		10.8		9.2		6.6		8.8		14.6		11.3		8.7		9.8		8.9			
		WC0118087	10.9	WC0118175	13.4	WC0118270	8.3	WC0120128	6.9	WC0118443	11.7	WC0118555	12.3	WC0118731	13.1	WC0118964	15.3	WC0119248	9.8	WC0119249	9.3	WC0119588	10.4	WC0119668	8.0	WC0119897	9.3	
			11.8		12.9		8.3		6.4		12.2		14.4		14.1		16.6		9.3		10.4		7.4		9.0			
		WC0118088	10.9	WC0118176	13.4	WC0118271	12.1	WC0118355	9.5	WC0118444	5.7	WC0118556	9.5	WC0118732	9.7	WC0118965	12.3	WC0119250	6.8	WC0119251	7.2	WC0119589	11.4	WC0119669	11.0			
			9.8		13.5		13.3		7.7		6.4		8.6		9.7		12.1		7.2		11.4		10.2					
		WC0118089	10.7	WC0118177	10.2	WC0118272	8.1	WC0118356	5.3	WC0118445	10.7	WC0118557	13.3	WC0118733	8.3	WC0118966	9.7	WC0119252	7.8	WC0119253	8.2	WC0119590	9.5	WC0119670	14.2			
			11.1		9.0		8.9		5.1		10.5		13.7		7.9		8.1		8.2		10.6		15.2					
		Unionised Ammonia mg/L	exceed 20%	WC0118076	0.001	WC0118041	0.001	WC0118068	0.002																			
					<0.001		0.001		0.002																			
				WC0118023	0.001	WC0118050	0.002																					
					0.003		0.002																					
		WC0118032	0.003	WC0118059	0.002																							
		Total Inorganic Nitrogen (as Nitrite + Nitrate) mg/L	exceed 20%	WC0118014	0.36	WC0118041	0.14	WC0118068	0.25																			
					0.35		0.16		0.27																			
				WC0118023	0.20	WC0118050	0.27																					
					0.19		0.24																					
		WC0118032	0.37	WC0118059	0.16																							

Total: 94

Total: 7

Total: 7