

Appendix F

The QA/QC Procedures and Results

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: R.E Site No.: Am1
 Date of visit: 13-4-04 Hour of Visit: 1020
 Staff name: W. C. MAK HVAS S/N: 2198
 Used filter paper no.: LQ82 New filter paper no.: LQ84
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 25.0}{298}$ K Pressure, $P_a = 1009$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading at site conditions corresponds to $Q_{STD} = 40$ ft ³ /min. (inch H ₂ O)
1534(04/2002)	$\Delta H_a = 18.0(T_a/P_a) =$ _____
✓ 1535(09/2003)	$\Delta H_a = 18.2(T_a/P_a) = 5.37^{\circ}$

Manometer reading before calibration: 5.40"
 Adjustment of flow controller (Y/N): N
 Manometer reading after calibration: 5.40"

Note: Tolerance Limit of HVAS flow: ± 1.0 ft³/min. Corresponding limits for manometer: ± 0.2 inch H₂O

III. General Conditions of HVAS

IV. Remarks

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: EC1 Site No.: Am2
 Date of visit: 13-4-04 Hour of Visit: 1115
 Staff name: W L MARK HVAS S/N: 2195
 Used filter paper no.: LQ83 New filter paper no.: LQ85
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = 273 + 25.9$ K Pressure, $P_a = 1011$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading at site conditions corresponds to $Q_{STD} = 40$ ft ³ /min. (inch H ₂ O)
1534(04/2002)	$\Delta H_a = 18.0(T_a/P_a) =$ _____
✓ 1535(09/2003)	$\Delta H_a = 18.2(T_a/P_a) = 5.38'$

Manometer reading before calibration: 5.10'

Adjustment of flow controller (Y/N): Y

Manometer reading after calibration: 5.30

Note: Tolerance Limit of HVAS flow: ± 1.0 ft³/min. Corresponding limits for manometer : ± 0.2 inch H₂O

III. General Conditions of HVAS

IV. Remarks

PARTISOL TSP SAMPLER
SITE VISIT LOG SHEET

Site Name: Ask Lygon Site Number: Am 3
Date of Visit: 13-4-04 Hour of Visit: 10:05
Staff Name: W. L. HAK ; H. K. TSANG Partisol S/N: 2000B 205500001
Used Filter No.: _____ New Filter No.: _____
Ambient temperature: 25.5°C Ambient pressure: 1013 mbar

I. General Services

1. Replace control unit Large In-line Filter X
2. Clean the sample inlet head ✓
3. Clean sample tube X
4. Clean / Replace pump head X
5. Clean / Replace piston X

II. Operational Audits (3 months interval as recommended by manufacturer)

1. Temperature Check (Ambient temperature $\pm 2^\circ\text{C}$)
_____ °C Calibration: Y/N _____ °C
Before After
2. Pressure Check (Ambient pressure ± 20 mbar)(factor = 0.000987)
_____ mbar Calibration: Y/N _____ mbar
Before After
3. Flow Check (16.7 \pm 1.1 litre/min)
_____ l/min Calibration: Y/N _____ l/min
Before After

III. Remarks

MINI VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: TXV Site No.: Am 4
Date of visit: 13-4-04 Hour of Visit: 11:30
Staff name: H. K. KANG MINIVOL S/N: 903
Used filter paper no.: M67C New filter paper no.: M67C

Type of filter: ~~Cellulose~~ / Glass-fibre
(Delete as appropriate)

- I. Calibration is performed by using Drycal DC-2 Flow Calibrator
5 Sl/min set point is recommended

5.00 Before 5.00 After

II. General Service of Mini Vol Air Sampler

1. Clean Rotameter: x
2. Clean / replace Pump Valves: x
3. Clean / replace Pump Diaphragms: x
4. Clean Impaction Inlet: ✓
5. Replace Timer Battery Every 6 months: x
6. Replace Inlet Filter: ✓

III. Remarks

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
TEOM 1400A CONTINUOUS DUST MONITOR
DATA QUALITY ASSURANCE LOG SHEET

Month : April

Year : 2004

Reservoir (AM1)					
Date	Frequency (Hz) (230 - 260)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 - 1.06)	Aux. Flow (l/min) (14.67 - 16.67)
6/4/2004	255.23	0.029	4	1.00	15.68
12/4/2004	254.93	0.030	4	1.00	15.68
18/4/2004	254.71	0.037	4	1.00	15.68
24/4/2004	254.53	0.054	4	1.00	15.68
30/4/2004	234.21	0.016	4	1.00	15.68

East Gate (AM2)					
Date	Frequency (Hz) (230 - 250)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 - 1.06)	Aux. Flow (l/min) (14.67 - 16.67)
6/4/2004	246.87	0.045	4	1.00	15.63
12/4/2004	246.56	0.027	4	1.00	15.64
18/4/2004	246.43	0.016	4	0.99	15.63
24/4/2004	247.13	0.041	4	1.00	15.63
30/4/2004	246.89	0.043	4	1.00	15.64

Ash Lagoon (AM3)					
Date	Frequency (Hz) (230 - 260)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 - 1.06)	Aux. Flow (l/min) (14.67 - 16.67)
6/4/2004	255.66	0.036	4	1.00	15.64
12/4/2004	255.10	0.021	4	1.00	15.63
18/4/2004	253.04	0.028	4	1.00	15.64
24/4/2004	254.75	0.047	4	0.99	15.63
30/4/2004	254.43	0.030	4	1.00	15.64

Maintenance Record			
	Reservoir	East Gate	Ash Lagoon
TEOM Filter Exchange	✓	✓	✓
Clean TSP Inlet	✓	✓	✓
Replace flow in-line filter			
Pump Repair			
Leak Check			
Flow Audit	✓		✓
Flow Controller Calibration			
A/C filter cleaning			

Remarks:

Prepared by : Alex

Checked by : Ronald

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/~~Ching Lam~~*

Date 13-4-04 Time 10:20

Equipment Rion NA-27 Sound Level Meter

Serial Number 00111465/~~00111466/00111467~~*

Staff Attended W.L. MAK ; H.K. TSANG

1. Calibration

Acoustic calibrator used Rion NC-74

Calibration level before adjustment (dB(A)) 94.0

Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

a. ~~Sunny/fine/cloudy/showery/heavy rain*~~

b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/Ching Lam*

Date 14-4-04 Time 14:10

Equipment BJK 2238F
~~Rion NA 27~~ Sound Level Meter

Serial Number 00111465/00111466/00111467* 2343838

Staff Attended W.L.MAK ; H.K.TSANG

1. Calibration

Acoustic calibrator used Rion NC-74

Calibration level before adjustment (dB(A)) 94.0

Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

a. ~~Sunny/fine/cloudy/showery/heavy rain*~~

b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate