

Appendix F

The QA/QC Procedures and Results

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: R-E Site No.: Am 1
 Date of visit: 20-1-2005 Hour of Visit: 0950
 Staff name: W. L. MAK HVAS S/N: 2198
 Used filter paper no.: LR 82 New filter paper no.: LR 84
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 19.8}{292.8}$ K Pressure, $P_a = 1023$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading at site conditions corresponds to $Q_{STD} = 40 \text{ ft}^3/\text{min.}$ (inch H_2O)
1534(09/2004)	$\Delta H_a = 18.33(T_a/P_a) = 5.24$

Manometer reading before calibration: 5.50"
 Adjustment of flow controller (Y/N): Y
 Manometer reading after calibration: 5.20"

Note: Tolerance Limit of HVAS flow: $\pm 1.0 \text{ ft}^3/\text{min.}$ Corresponding limits for manometer : $\pm 0.2 \text{ inch H}_2\text{O}$

III. General Conditions of HVAS

IV. Remarks

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: E-61 Site No.: Am 2
 Date of visit: 20-1-2005 Hour of Visit: 1055
 Staff name: W. L. MAK / H. K. TSANG HVAS S/N: 2195
 Used filter paper no.: LR83 New filter paper no.: LR85
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 18.0}{291.0}$ K Pressure, $P_a = 1025$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading at site conditions corresponds to $Q_{STD} = 40 \text{ ft}^3/\text{min.}$ (inch H_2O)
1534(09/2004)	$\Delta H_a = 18.33(T_a/P_a) = 5.20''$

Manometer reading before calibration: 5.50''
 Adjustment of flow controller (Y/N): Y
 Manometer reading after calibration: 5.20''

Note: Tolerance Limit of HVAS flow: $\pm 1.0 \text{ ft}^3/\text{min.}$ Corresponding limits for manometer : $\pm 0.2 \text{ inch H}_2\text{O}$

III. General Conditions of HVAS

IV. Remarks

PARTISOL TSP SAMPLER
SITE VISIT LOG SHEET

Site Name: AL Site Number: AM 3
Date of Visit: 20-1-05 Hour of Visit: 10:20
Staff Name: H.K. Tsang Partisol S/N: 20008205500001
Used Filter No.: PC 37 New Filter No.: PC 38
Ambient temperature: 18.9 Ambient pressure: 1025 mbar

I. General Services

1. Replace control unit Large In-line Filter X
2. Clean the sample inlet head ✓
3. Clean sample tube ✓
4. Clean / ~~Replace~~ pump head ✓
5. Clean / ~~Replace~~ piston ✓

II. Operational Audits (3 months interval as recommended by manufacturer)

1. Temperature Check (Ambient temperature $\pm 2^{\circ}\text{C}$)

19 $^{\circ}\text{C}$ Before Calibration: Y/N 19 $^{\circ}\text{C}$ After

2. Pressure Check (Ambient pressure ± 20 mbar)(factor = 0.000987)

1.008 ~~AM~~ mbar Before Calibration: Y/N 1021 mbar After

3. Flow Check (16.7 \pm 1.1 litre/min)

17.0 l/min Before Calibration: Y/N 17.0 l/min After

III. Remarks

MINI VOLUME AIR SAMPLER

SITE VISIT LOG SHEET

Site Name: TYV Site No.: AM4

Date of visit: 10-1-05 Hour of Visit: 11:00

Staff name: W.L.MAK, H.K. TING MINIVOL S/N: 33P2

Used filter paper no.: MH20 New filter paper no.: MH21

Type of filter: ~~Cellulose~~ / Glass-fibre
(Delete as appropriate)

I. Calibration is performed by using Drycal DC-2 Flow Calibrator

5 Sl/min set point is recommended

5.0 Before 5.0 After

II. General Service of Mini Vol Air Sampler

1. Clean Rotameter: ✓
2. Clean / ~~replace~~ Pump Valves: ✓
3. Clean / ~~replace~~ Pump Diaphragms: ✓
4. Clean Impaction Inlet: ✓
5. Replace Timer Battery Every 6 months: ✓
6. Replace Inlet Filter: ✓

III. Remarks

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
TEOM 1400A CONTINUOUS DUST MONITOR
DATA QUALITY ASSURANCE LOG SHEET

Month : January

Year : 2005

Reservoir (AM1)					
Date	Frequency (Hz) (230 – 260)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
1/1/2005	233.63	0.034	4	1.00	15.68
7/1/2005	233.42	0.037	4	1.00	15.68
13/1/2005	234.09	0.046	4	1.00	15.68
19/1/2005	233.67	0.038	4	1.00	15.68
25/1/2005	233.35	0.036	4	1.00	15.68
31/1/2005	233.21	0.052	4	1.00	15.68

East Gate (AM2)					
Date	Frequency (Hz) (230 – 250)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
1/1/2005	245.02	0.039	4	1.00	15.65
7/1/2005	244.41	0.041	4	1.01	15.64
13/1/2005	245.79	0.029	4	0.99	15.65
19/1/2005	245.37	0.048	4	0.99	15.65
25/1/2005	245.05	0.041	4	1.00	15.64
31/1/2005	244.91	0.045	4	0.99	15.66

Ash Lagoon (AM3)					
Date	Frequency (Hz) (230 – 260)	Noise (< 0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
1/1/2005	261.80	0.048	4	1.01	15.68
7/1/2005	261.19	0.029	4	1.01	15.68
13/1/2005	260.66	0.040	4	1.01	15.68
19/1/2005	260.22	0.027	4	1.01	15.68
25/1/2005	262.15	0.040	4	1.01	15.69
31/1/2005	262.05	0.032	4	1.01	15.68

Maintenance Record			
	Reservoir	East Gate	Ash Lagoon
TEOM Filter Exchange	✓	✓	✓
Clean TSP Inlet	✓	✓	✓
Replace flow in-line filter			
Pump Repair			
Leak Check			
Flow Audit	✓		
Flow Controller Calibration			
A/C filter cleaning	✓	✓	✓

Remarks:

Prepared by : Alex

Checked by : [Signature]

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/Ching Lam*

Date 14-1-05 Time 10:40.

Equipment Rion NA-27/B&K ~~2238P~~* Sound Level Meter

Serial Number 00111465/~~00111466~~/~~00111467~~/~~2343838~~/~~2356907~~*

Staff Attended W.L. MAK ; H.K. TSANG

1. Calibration

Acoustic calibrator used Rion NC-74

Calibration level before adjustment (dB(A)) 94.0

Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

- a. ~~Sunny/fine/cloudy/showery/heavy rain*~~
- b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

18/5/2004

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location ~~Ash Lagoon~~/Ching Lam*

Date 14-1-05 Time 11:20

Equipment Rion ~~NA-27~~/B&K 2238F* Sound Level Meter

Serial Number ~~00111465/00111466/00111467/2343838/2356907*~~

Staff Attended W.L. MAK ; H.K. TSANG

1. Calibration

Acoustic calibrator used Rion NC-74

Calibration level before adjustment (dB(A)) 94.0

Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

a. ~~Sunny/fine/cloudy/showery/heavy rain*~~

b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

Equipment Calibration Record

Site: Civil works for 275kV Cable Route from Lamma Island to Cyberport

Noise Equipment Used: RION NL-31

Calibrator Used: RION NC-74

Measurement Location: N4 – Pak Kok Tsui No. 2

Date	Calibration Level before Measurement (dB(A))	Calibration Level after Measurement (dB(A))	Calibrated by
04/01/2005	94.0	94.0	Anthony Wong
07/01/2005	94.0	94.0	Anthony Wong
11/01/2005	94.0	94.0	Anthony Wong
14/01/2005	94.0	94.0	Anthony Wong
18/01/2005	94.0	94.0	Anthony Wong
21/01/2005	94.0	94.0	Anthony Wong
25/01/2005	94.0	94.0	Anthony Wong
28/01/2005	94.0	94.0	Anthony Wong

Measurement Location: N5 – Pak Kok Tsui No. 8

Date	Calibration Level before Measurement (dB(A))	Calibration Level after Measurement (dB(A))	Calibrated by
04/01/2005	94.0	94.0	Anthony Wong
07/01/2005	94.0	94.0	Anthony Wong
11/01/2005	94.0	94.0	Anthony Wong
14/01/2005	94.0	94.0	Anthony Wong
18/01/2005	94.0	94.0	Anthony Wong
21/01/2005	94.0	94.0	Anthony Wong
25/01/2005	94.0	94.0	Anthony Wong
28/01/2005	94.0	94.0	Anthony Wong

Note: Measurement accepted as valid only if the calibration levels from before and after the noise measurement agreed to within 1.0 dB.