

Appendix F

The QA/QC Procedures and Results

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: RE Site No.: Am1
 Date of visit: 17-5-2005 Hour of Visit: 14.15
 Staff name: w l malk HVAS S/N: 2198
 Used filter paper no.: LS20 New filter paper no.: LS22
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 37.1}{306.1}$ K Pressure, $P_a = 1009$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading at site conditions corresponds to $Q_{STD} = 40$ ft ³ /min. (inch H ₂ O)
1534(09/2004)	$\Delta H_a = 18.33(T_a/P_a) = 5.56$

Manometer reading before calibration: 5.30
 Adjustment of flow controller (Y/N): Y
 Manometer reading after calibration: 5.50

Note: Tolerance Limit of HVAS flow: ± 1.0 ft³/min. Corresponding limits for manometer : ± 0.2 inch H₂O

III. General Conditions of HVAS

IV. Remarks

HIGH VOLUME AIR SAMPLER
SITE VISIT LOG SHEET

Site Name: EG Site No.: Atm 2
 Date of visit: 17-5-2005 Hour of Visit: 1320
 Staff name: W L M P K / H K T S P K S HVAS S/N: 2195
 Used filter paper no.: L521 New filter paper no.: L523
 Type of filter: Glass-fibre

I. Ambient Conditions

Temperature, $T_a = \frac{273 + 33.4}{366.4}$ K Pressure, $P_a = 1014$ mb

II. Correction of manometer reading

Calibration orifice No.	Manometer reading at site conditions corresponds to $Q_{STD} = 40$ ft ³ /min. (inch H ₂ O)
1534(09/2004)	$\Delta H_a = 18.33(T_a/P_a) = 5.53$

Manometer reading before calibration: 5.10
 Adjustment of flow controller (Y/N): Y
 Manometer reading after calibration: 5.50

Note: Tolerance Limit of HVAS flow: ± 1.0 ft³/min. Corresponding limits for manometer: ± 0.2 inch H₂O

III. General Conditions of HVAS

IV. Remarks

PARTISOL TSP SAMPLER
SITE VISIT LOG SHEET

Site Name A.L. Site Number Am 3
Date of Visit 17-5-05 Hour of Visit 14:35
Staff Name H.K. Tsang Partisol S/N: 2000B 20550001
Used Filter No.: Pc56 New Filter No.: Pc57
Ambient temperature: 35.4° C Ambient pressure: 1016

I. General Services

1. Replace control unit Large In-line Filter X
2. Clean the sample inlet head ✓
3. Clean sample tube ✓
4. Clean / Replace pump head X
5. Clean / ~~Replace~~ piston ✓

II. Operational Audits (3 months interval as recommended by manufacturer)

1. Temperature Check (Ambient temperature $\pm 2^{\circ}\text{C}$)

_____ $^{\circ}\text{C}$ Calibration: Y/N _____ $^{\circ}\text{C}$
Before After

2. Pressure Check (Ambient pressure ± 20 mbar)(factor = 0.000987)

_____ mbar Calibration: Y/N _____ mbar
Before After

3. Flow Check (16.7 \pm 1.1 litre/min)

_____ cc/min Calibration: Y/N _____ cc/min
~~Before~~

III. REMARKS

MINI VOLUME AIR SAMPLER

SITE VISIT LOG SHEET

Site Name: TYV Site No.: AM

Date of visit: 17-5-05 Hour of Visit: 14:10

Staff name: H.K. ISAMB MINIVOL S/N: 3393

Used filter paper no.: MH 41 New filter paper no.: MH 42.

Type of filter: ~~Cellulose~~ / Glass-fibre
(Delete as appropriate)

- I. Calibration is performed by using Drycal DC-2 Flow Calibrator
5 Sl/min set point is recommended

5.02 Before 5.02 After

II. General Service of Mini Vol Air Sampler

1. Clean Rotameter: x
2. Clean / replace Pump Valves: ✓
3. Clean / replace Pump Diaphragms: x
4. Clean Impaction Inlet: ✓
5. Replace Timer Battery Every 6 months: x
6. Replace Inlet Filter: ✓

III. Remarks

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
TEOM 1400A CONTINUOUS DUST MONITOR
DATA QUALITY ASSURANCE LOG SHEET

Month : May Year : 2005

Reservoir (AM1)					
Date	Frequency (Hz) (230 – 260)	Noise (<0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
1/5/2005	257.2	0.037	4	1.00	15.68
7/5/2005	256.9	0.036	4	1.00	15.68
13/5/2005	256.8	0.043	4	1.00	15.68
19/5/2005	256.6	0.039	4	1.00	15.68
25/5/2005	256.5	0.036	4	1.00	15.68
31/5/2005	257.5	0.043	4	1.00	15.68

East Gate (AM2)					
Date	Frequency (Hz) (230 – 250)	Noise (<0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
1/5/2005	245.4	0.050	4	0.99	15.65
7/5/2005	245.2	0.050	4	1.00	15.64
13/5/2005	245.1	0.041	4	1.00	15.57
19/5/2005	246.4	0.031	4	1.00	15.57
25/5/2005	246.2	0.038	4	0.99	15.64
31/5/2005	246.1	0.033	4	0.99	15.63

Ash Lagoon (AM3)					
Date	Frequency (Hz) (240 – 270)	Noise (<0.1)	Operation Mode (Mode 4)	Main Flow (l/min) (0.94 – 1.06)	Aux. Flow (l/min) (14.67 – 16.67)
1/5/2005	246.8	0.024	4	1.01	15.67
7/5/2005	246.6	0.029	4	1.00	15.67
13/5/2005	247.8	0.030	4	1.00	15.67
19/5/2005	247.7	0.031	4	1.00	15.67
25/5/2005	247.5	0.030	4	1.00	15.67
31/5/2005	247.4	0.033	4	1.00	15.67

Maintenance Record			
	Reservoir	East Gate	Ash Lagoon
TEOM Filter Exchange	✓	✓	✓
Clean TSP Inlet	✓	✓	✓
Replace flow in-line filter	✓		
Pump Repair			
Leak Check			
Flow Audit		✓	
Flow Controller Calibration			
A/C filter cleaning	✓	✓	✓

Remarks:

Prepared by : Alex

Checked by : Ch

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/Ching Lam*

Date 11-5-05 Time 15:00

Equipment Rion NA-27/B&K 2238F* Sound Level Meter

Serial Number 00111465/00111466/00111467/2343838/2356907*

Staff Attended W.L.MAK ; H.K.TSANG

1. Calibration

Acoustic calibrator used Rion NC-74

Calibration level before adjustment (dB(A)) 94.0

Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

a. ~~Sunny/fine/cloudy/showery/heavy rain*~~

b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

18/5/2004

THE HONGKONG ELECTRIC CO., LTD.
LAMMA POWER STATION EXTENSION
NOISE MONITORING STATION
SITE VISIT LOG SHEET

Location Ash Lagoon/~~Ching Lam*~~

Date 20-5-05 Time 13:10

Equipment Rion NA-27/~~B&K 2238F*~~ Sound Level Meter

Serial Number 00111465/00111466/00111467/~~2343838/2356907*~~

Staff Attended W.L.MAK ; H.K.TSANG

1. Calibration

Acoustic calibrator used Rion NC-74

Calibration level before adjustment (dB(A)) 94.0

Calibration level after adjustment (dB(A)) 94

2. Weather Conditions

a. ~~Sunny/fine/cloudy/showery/heavy rain*~~

b. ~~Strong wind/breeze/calm*~~

3. Remark/Observation

Note: * - Please delete where inappropriate

Equipment Calibration Record for May 2005

Site: Civil works for 275kV Cable Route from Lamma Island to Cyberport

Noise Equipment Used: RION NL-31

Calibrator Used: RION NC-74

Measurement Location: N4 – Pak Kok Tsui No. 2

Date	Calibration Level before Measurement (dB(A))	Calibration Level after Measurement (dB(A))	Calibrated by
03/05/2005	94.0	94.0	Anthony Wong
06/05/2005	94.0	94.0	Anthony Wong
10/05/2005	94.0	94.0	Anthony Wong
13/05/2005	94.0	94.0	Anthony Wong
17/05/2005	94.0	94.0	Anthony Wong
20/05/2005	94.0	94.0	Anthony Wong
24/05/2005	94.0	94.0	Anthony Wong
27/05/2005	94.0	94.0	Anthony Wong
31/05/2005	94.0	94.0	Anthony Wong

Measurement Location: N5 – Pak Kok Tsui No. 8

Date	Calibration Level before Measurement (dB(A))	Calibration Level after Measurement (dB(A))	Calibrated by
03/05/2005	94.0	94.0	Anthony Wong
06/05/2005	94.0	94.0	Anthony Wong
10/05/2005	94.0	94.0	Anthony Wong
13/05/2005	94.0	94.0	Anthony Wong
17/05/2005	94.0	94.0	Anthony Wong
20/05/2005	94.0	94.0	Anthony Wong
24/05/2005	94.0	94.0	Anthony Wong
27/05/2005	94.0	94.0	Anthony Wong
31/05/2005	94.0	94.0	Anthony Wong

Note: Measurement accepted as valid only if the calibration levels from before and after the noise measurement agreed to within 1.0 dB.