

**The Hongkong Electric Co., Ltd.**  
**Lamma Power Station Extension**  
**TEOM Continuous Dust Monitor**  
**Data Quality Assurance Log Sheet**

Month: July Year: 2020

| Reservoir (AM1) |                               |                            |                                    |  |
|-----------------|-------------------------------|----------------------------|------------------------------------|--|
| Date            | Frequency (Hz)<br>(240 - 275) | Operation Mode<br>(Mode 4) | Main Flow (l/min)<br>(2.70 - 3.30) | Bypass Flow (l/min)<br>(12.30 - 15.04) |
| 05/07/2020      | 268.225                       | 4                          | 2.93                               | 13.34                                  |
| 11/07/2020      | 267.715                       | 4                          | 2.93                               | 13.36                                  |
| 17/07/2020      | 267.376                       | 4                          | 2.91                               | 13.26                                  |
| 23/07/2020      | 269.786                       | 4                          | 2.92                               | 13.31                                  |
| 29/07/2020      | 269.455                       | 4                          | 2.92                               | 13.32                                  |

| East Gate (AM2) |                               |                            |                                    |  |
|-----------------|-------------------------------|----------------------------|------------------------------------|--|
| Date            | Frequency (Hz)<br>(240 - 275) | Operation Mode<br>(Mode 4) | Main Flow (l/min)<br>(2.70 - 3.30) | Bypass Flow (l/min)<br>(12.30 - 15.04) |
| 05/07/2020      | 255.773                       | 4                          | 2.96                               | 13.47                                  |
| 11/07/2020      | 255.196                       | 4                          | 2.98                               | 13.54                                  |
| 17/07/2020      | 254.697                       | 4                          | 2.96                               | 13.48                                  |
| 23/07/2020      | 257.286                       | 4                          | 2.95                               | 13.43                                  |
| 29/07/2020      | 257.003                       | 4                          | 2.97                               | 13.53                                  |

| Ash Lagoon (AM3) |                               |                            |                                    |  |
|------------------|-------------------------------|----------------------------|------------------------------------|--|
| Date             | Frequency (Hz)<br>(240 - 275) | Operation Mode<br>(Mode 4) | Main Flow (l/min)<br>(2.70 - 3.30) | Bypass Flow (l/min)<br>(12.30 - 15.04) |
| 05/07/2020       | 255.468                       | 4                          | 3.00                               | 13.68                                  |
| 11/07/2020       | 255.218                       | 4                          | 3.00                               | 13.37                                  |
| 17/07/2020       | 255.041                       | 4                          | 3.00                               | 13.40                                  |
| 23/07/2020       | 254.923                       | 4                          | 3.00                               | 13.67                                  |
| 29/07/2020       | 256.522                       | 4                          | 3.00                               | 13.66                                  |

| Maintenance Record          |           |           |            |
|-----------------------------|-----------|-----------|------------|
|                             | Reservoir | East Gate | Ash Lagoon |
| TEOM Filter Exchange        | ✓         | ✓         | ✓          |
| Clean TSP Inlet             | ✓         | ✓         | ✓          |
| Replace flow in-line filter | ✓         | ✓         | ✓          |
| Pump Repair                 |           |           |            |
| Leak Check                  |           |           |            |
| Flow audit                  |           |           |            |
| Flow Controller Calibration |           |           |            |
| A/C filter cleaning         |           |           |            |

Remarks:

Prepared by: Chris Chan

Checked by: HY Chan

**The Hongkong Electric Co., Ltd.**  
**Mini Volume Air Sampler Site Visit Log Sheet**

Attendance Log

Site Name: Tai Yuen Village (AM4)

| Date / Time      | Staff Name |
|------------------|------------|
| 07/14/2020 10:45 | WM Tam     |

Equipment / Item

| Equipment / Item      | Serial No. / No. |
|-----------------------|------------------|
| MINIVOL               | 5580             |
| Used Filter Paper No. | MQ86             |
| New Filter Paper No.  | MQ87             |

Type of filter: Glass-fibre

- I. Calibration is performed by using Drycal DC-2 Flow Calibrator  
5 std. L/min set point is recommended

Before: 5.08  
After: 5.02

- II. General Services

1. Clean Rotameter: Yes
2. Clean / Replace Pump Valves: No
3. Clean / Replace Pump Diaphragms: No
4. Clean Impaction Inlet: Yes
5. Replace Timer Battery Every 6 months: Yes
6. Replace Inlet Filter: Yes

- III. Remarks

N/A

Conducted by: WM Tam

Checked by: SM Hon

**The Hongkong Electric Co., Ltd.**  
**Lamma Power Station Extension**  
**Noise Monitoring Stations**  
**Daily Calibration Records**

| Date       | Location: Ash Lagoon |                               | Location: Ching Lam |                               |
|------------|----------------------|-------------------------------|---------------------|-------------------------------|
|            | Calibration Results  | Deviation from Reference (dB) | Calibration Results | Deviation from Reference (dB) |
| 01/07/2020 | Passed               | -0.01                         | Passed              | 0.00                          |
| 02/07/2020 | Passed               | -0.03                         | Passed              | 0.01                          |
| 03/07/2020 | Passed               | -0.01                         | Passed              | 0.02                          |
| 04/07/2020 | Passed               | 0.00                          | Passed              | 0.01                          |
| 05/07/2020 | Passed               | 0.00                          | Passed              | 0.03                          |
| 06/07/2020 | Passed               | 0.00                          | Passed              | 0.02                          |
| 07/07/2020 | Passed               | -0.03                         | Passed              | 0.02                          |
| 08/07/2020 | Passed               | 0.00                          | Passed              | 0.02                          |
| 09/07/2020 | Passed               | 0.00                          | Passed              | 0.01                          |
| 10/07/2020 | Passed               | 0.00                          | Passed              | 0.01                          |
| 11/07/2020 | Passed               | 0.00                          | Passed              | 0.02                          |
| 12/07/2020 | Passed               | 0.01                          | Passed              | 0.02                          |
| 13/07/2020 | Passed               | -0.02                         | Passed              | -0.01                         |
| 14/07/2020 | Passed               | -0.02                         | Passed              | 0.00                          |
| 15/07/2020 | Passed               | -0.01                         | Passed              | 0.02                          |
| 16/07/2020 | Passed               | 0.00                          | Passed              | 0.03                          |
| 17/07/2020 | Passed               | 0.01                          | Passed              | 0.02                          |
| 18/07/2020 | Passed               | 0.01                          | Passed              | 0.03                          |
| 19/07/2020 | Passed               | 0.00                          | Passed              | 0.02                          |
| 20/07/2020 | Passed               | -0.01                         | Passed              | 0.00                          |
| 21/07/2020 | Passed               | 0.00                          | Passed              | 0.01                          |
| 22/07/2020 | Passed               | 0.01                          | Passed              | 0.02                          |
| 23/07/2020 | Passed               | 0.01                          | Passed              | 0.01                          |
| 24/07/2020 | Passed               | -0.01                         | Passed              | 0.00                          |
| 25/07/2020 | Passed               | -0.01                         | Passed              | 0.01                          |
| 26/07/2020 | Passed               | 0.01                          | Passed              | 0.06                          |
| 27/07/2020 | Passed               | -0.02                         | Passed              | 0.02                          |
| 28/07/2020 | Passed               | 0.01                          | Passed              | 0.03                          |
| 29/07/2020 | Passed               | 0.00                          | Passed              | 0.00                          |
| 30/07/2020 | Passed               | 0.00                          | Passed              | -0.01                         |
| 31/07/2020 | Passed               | 0.00                          | Passed              | -0.01                         |

Remarks:

1. The B&K sound level meter at the noise monitoring station has an advanced feature of internal calibration checking (viz. Charge Injection Calibration (CIC)). CIC is a B&K patented method for in situ verification of the integrity of the entire sound measurement chain (including microphone, preamplifier and cabling).
2. The acceptance criterion of deviation from reference is  $\pm 0.5$  dB.