

**The Hongkong Electric Co., Ltd.**  
**Lamma Power Station Extension**  
**TEOM Continuous Dust Monitor**  
**Data Quality Assurance Log Sheet**

Month: October

Year: 2022

| Reservoir (AM1) |                               |                            |                                    |  |
|-----------------|-------------------------------|----------------------------|------------------------------------|--|
| Date            | Frequency (Hz)<br>(240 - 275) | Operation Mode<br>(Mode 4) | Main Flow (l/min)<br>(2.70 - 3.30) | Bypass Flow (l/min)<br>(12.30 - 15.04) |
| 4/10/2022       | 267.657                       | 4                          | 2.85                               | 10.31                                  |
| 10/10/2022      | 271.169                       | 4                          | 2.92                               | 10.31                                  |
| 16/10/2022      | 270.257                       | 4                          | 2.85                               | 10.31                                  |
| 22/10/2022      | 269.324                       | 4                          | 2.89                               | 10.31                                  |
| 28/10/2022      | 268.685                       | 4                          | 2.88                               | 10.31                                  |

| East Gate (AM2) |                               |                            |                                    |  |
|-----------------|-------------------------------|----------------------------|------------------------------------|--|
| Date            | Frequency (Hz)<br>(240 - 275) | Operation Mode<br>(Mode 4) | Main Flow (l/min)<br>(2.70 - 3.30) | Bypass Flow (l/min)<br>(12.30 - 15.04) |
| 4/10/2022       | 265.340                       | 4                          | 2.95                               | 13.44                                  |
| 10/10/2022      | 265.012                       | 4                          | 2.88                               | 13.88                                  |
| 16/10/2022      | 264.116                       | 4                          | 2.16                               | 13.28                                  |
| 22/10/2022      | 263.454                       | 4                          | 2.38                               | 13.70                                  |
| 28/10/2022      | 263.110                       | 4                          | 2.16                               | 13.68                                  |

| Ash Lagoon (AM3) |                               |                            |                                    |  |
|------------------|-------------------------------|----------------------------|------------------------------------|--|
| Date             | Frequency (Hz)<br>(240 - 275) | Operation Mode<br>(Mode 4) | Main Flow (l/min)<br>(2.70 - 3.30) | Bypass Flow (l/min)<br>(12.30 - 15.04) |
| 4/10/2022        | 257.125                       | 4                          | 2.60                               | 13.68                                  |
| 10/10/2022       | 256.786                       | 4                          | 2.31                               | 13.68                                  |
| 16/10/2022       | 256.189                       | 4                          | 2.12                               | 13.67                                  |
| 22/10/2022       | 258.280                       | 4                          | 3.00                               | 13.69                                  |
| 28/10/2022       | 257.746                       | 4                          | 3.00                               | 13.68                                  |

| Maintenance Record          |           |           |            |
|-----------------------------|-----------|-----------|------------|
|                             | Reservoir | East Gate | Ash Lagoon |
| TEOM Filter Exchange        | ✓         | ✓         | ✓          |
| Clean TSP Inlet             | ✓         | ✓         | ✓          |
| Replace flow in-line filter | ✓         | ✓         | ✓          |
| Pump Repair                 |           |           |            |
| Leak Check                  |           |           |            |
| Flow audit                  |           |           |            |
| Flow Controller Calibration |           |           |            |
| A/C filter cleaning         |           |           |            |

Remarks:

Prepared by: Chris Chan

Checked by: HY Chan

**The Hongkong Electric Co., Ltd.**  
**Mini Volume Air Sampler Site Visit Log Sheet**

Attendance Log \_\_\_\_\_

Site Name: Tai Yuen Village (AM4)

| Date/Time          | Staff Name |
|--------------------|------------|
| 19/10/2022 / 10:15 | WM Tam     |

Equipment / Item

| Equipment / Item      | Serial No. / No. |
|-----------------------|------------------|
| MINIVOL               | 5580             |
| Used filter paper no. | MS25             |
| New filter paper no.  | MS26             |

Type of filter: Glass-fibre

- I. Calibration is performed by using Drycal DC-2 Flow Calibrator  
5 std. L/min set point is recommended

Before: 5.041  
After: 5.041 (No adjustment)

- II. General Services

1. Clean Rotameter: Yes
2. Clean / Replace Pump Valves: No
3. Clean / Replace Pump Diaphragms: No
4. Clean Impaction Inlet: Yes
5. Replace Timer Battery Every 6 months: No
6. Replace Inlet Filter: Yes

Remarks

N/A

Conducted by: WM Tam

Checked by: SM Hon

**The Hongkong Electric Co., Ltd.**  
**Lamma Power Station Extension**  
**Noise Monitoring Station**  
**Daily Calibration Records**

| Date       | Location: Ash Lagoon |                               | Location: Ching Lam |                               |
|------------|----------------------|-------------------------------|---------------------|-------------------------------|
|            | Calibration Results  | Deviation from Reference (dB) | Calibration Results | Deviation from Reference (dB) |
| 01/10/2022 | Passed               | 0.03                          | Passed              | 0.02                          |
| 02/10/2022 | Passed               | 0.04                          | Passed              | 0.06                          |
| 03/10/2022 | Passed               | 0.03                          | Passed              | 0.04                          |
| 04/10/2022 | Passed               | 0.07                          | Passed              | 0.05                          |
| 05/10/2022 | Passed               | 0.03                          | Passed              | 0.04                          |
| 06/10/2022 | Passed               | 0.03                          | Passed              | 0.05                          |
| 07/10/2022 | Passed               | 0.04                          | Passed              | 0.02                          |
| 08/10/2022 | Passed               | 0.02                          | Passed              | 0.03                          |
| 09/10/2022 | Passed               | 0.01                          | Passed              | 0.02                          |
| 10/10/2022 | Passed               | 0.00                          | Passed              | 0.00                          |
| 11/10/2022 | Passed               | -0.01                         | Passed              | -0.02                         |
| 12/10/2022 | Passed               | 0.00                          | Passed              | -0.01                         |
| 13/10/2022 | Passed               | 0.00                          | Passed              | 0.01                          |
| 14/10/2022 | Passed               | 0.03                          | Passed              | 0.01                          |
| 15/10/2022 | Passed               | 0.04                          | Passed              | 0.03                          |
| 16/10/2022 | Passed               | 0.03                          | Passed              | 0.01                          |
| 17/10/2022 | Passed               | -0.05                         | Passed              | -0.07                         |
| 18/10/2022 | Passed               | -0.01                         | Passed              | -0.02                         |
| 19/10/2022 | Passed               | 0.00                          | Passed              | -0.01                         |
| 20/10/2022 | Passed               | -0.02                         | Passed              | -0.02                         |
| 21/10/2022 | Passed               | 0.01                          | Passed              | 0.02                          |
| 22/10/2022 | Passed               | 0.02                          | Passed              | -0.01                         |
| 23/10/2022 | Passed               | -0.04                         | Passed              | -0.02                         |
| 24/10/2022 | Passed               | -0.04                         | Passed              | -0.03                         |
| 25/10/2022 | Passed               | -0.03                         | Passed              | -0.03                         |
| 26/10/2022 | Passed               | -0.03                         | Passed              | 0.00                          |
| 27/10/2022 | Passed               | -0.01                         | Passed              | -0.02                         |
| 28/10/2022 | Passed               | 0.00                          | Passed              | 0.00                          |
| 29/10/2022 | Passed               | 0.02                          | Passed              | 0.00                          |
| 30/10/2022 | Passed               | 0.02                          | Passed              | 0.00                          |
| 31/10/2022 | Passed               | -0.05                         | Passed              | -0.05                         |

Remarks:

1. The B&K sound level meter at the noise monitoring station has an advanced feature of internal calibration checking (viz. Charge Injection Calibration (CIC)). CIC is a B&K patented method for in situ verification of the integrity of the entire sound measurement chain (including microphone, preamplifier and cabling).
2. The acceptance criterion of deviation from reference is  $\pm 0.5$  dB.